

# FABIUS-POMPEY CENTRAL SCHOOL DISTRICT


1211 Mill Street  
FABIUS, NEW YORK 13063

## BOARD OF EDUCATION

Donald Neugebauer, President  
Maryam Wasmund, Vice-President  
Andrew Aiken  
Eric Exelby  
William Heselden IV  
Sheila Larkin  
John Repak



MIDDLE SCHOOL- HIGH SCHOOL  
(315) 683-5811



ELEMENTARY SCHOOL  
(315) 683-5857

SUPERINTENDENT OF SCHOOLS  
Timothy P. Ryan

DISTRICT OFFICE  
(315) 683-5301 / FAX (315) 683-5827

BUSINESS ADMINISTRATOR  
Peter W. Mahunik

October 26, 2016

Dear Parents/Guardians:

As you may be aware, Governor Andrew Cuomo signed a new law on September 6, 2016 that requires public school districts to test for lead levels in all water outlets currently or potentially used for drinking or cooking. In accordance with the new law, this letter is being sent to inform you about recent water testing completed in the Fabius-Pompey Elementary School.

The district has taken water samples from 74 outlets within the Elementary School. The vast majority of the outlets, including all drinking fountains, were found to be well within the acceptable limits.

Under the State's standard, water sources that could potentially be used for drinking or cooking that are found to have lead levels greater than 15 parts per billion (ppb) are to be taken out of service until corrected. A sink that is important for hand washing may remain in service and labeled "DO NOT DRINK" until remediated.

The table on the back of this letter lists fixtures which had readings above 15 ppb after the initial testing. With the exception of the kitchen sinks, in general the outlets listed are not normally used for drinking water. All outlets above 15 ppb have either been labeled "DO NOT DRINK", or have been taken out of service, until remediation efforts are completed.

Follow-up testing on each fixture will be performed to ensure safe levels before returning to service.

As remediations are made, additional information and complete water testing results will become available on the district website.

Please contact me if you have any questions.

Sincerely,

Timothy P. Ryan  
Superintendent of Schools  
(315) 683-5301  
[tryan@fabiuspompey.org](mailto:tryan@fabiuspompey.org)

Date	Location	Results	Action
9/22/2016	Boys Locker Room	15 ppb	Posted Sign
9/22/2016	Gym Office Sink - Boys	30 ppb	Posted Sign
9/22/2016	Gym Office Sink - Girls	25 ppb	Posted Sign
9/22/2016	Main Office Sink	23 ppb	Posted Sign
9/22/2016	Kitchen Sink	45 ppb	Turned Off
9/22/2016	Kitchen Sink	16 ppb	Turned Off
9/22/2016	Kitchen Sink	87 ppb	Turned Off
9/22/2016	Kitchen Sink	47 ppb	Turned Off
9/22/2016	Girls Lav. 1st Floor	15 ppb	Posted Sign
9/22/2016	Room 5 Sink	77 ppb	Turned Off
9/22/2016	Room 7 Sink	17 ppb	Turned Off
9/22/2016	Room 11 Sink	19 ppb	Turned Off
9/22/2016	Room 109 Sink	21 ppb	Turned Off
9/22/2016	Room 110 Sink	15 ppb	Turned Off
9/22/2016	Room 111 Sink	45 ppb	Turned Off
9/22/2016	Room 112 Sink	15 ppb	Turned Off
9/22/2016	Boys Lav. 2nd Floor	31 ppb	Posted Sign
9/22/2016	Library Office Sink	29 ppb	Turned Off
9/22/2016	Room 210 Sink	20 ppb	Turned Off

ppb = parts per billion