


FABIUS-POMPEY CENTRAL SCHOOL DISTRICT


1211 Mill Street
FABIUS, NEW YORK 13063

BOARD OF EDUCATION

Donald Neugebauer, President
Maryam Wasmund, Vice-President
Andrew Aiken
Eric Exelby
William Heselden IV
Sheila Larkin
John Repak



MIDDLE SCHOOL - HIGH SCHOOL
(315) 683-5811



ELEMENTARY SCHOOL
(315) 683-5857

SUPERINTENDENT OF SCHOOLS

Timothy P. Ryan

DISTRICT OFFICE

(315) 683-5301 / FAX (315) 683-5827

BUSINESS ADMINISTRATOR

Peter W. Mahunik

January 3, 2017

Dear Parents/Guardians:

As you may already know, Governor Cuomo signed a law on September 6, 2016 that requires public school districts to test for lead levels in all water outlets currently or potentially used for drinking or cooking. In accordance with this new law, this letter is being sent to inform you about recent water testing completed in the Fabius-Pompey Middle School-High School.

The district has taken water samples from the 73 outlets within the Middle School-High School. The majority of the outlets were found to be well within the acceptable limits.

Under the State's standard, water sources that could potentially be used for drinking or cooking that are found to have lead levels greater than 15 parts per billion (ppb) are to be taken out of service until corrected. A sink that is important for hand washing may remain in service and labeled "DO NOT DRINK", until remediated.

The table on the back of this letter lists fixtures which had readings above 15 ppb after the initial testing. With the exception of two drinking fountains, in general the outlets listed are not normally used for drinking water. All outlets above 15 ppb have either been labeled "DO NOT DRINK", or have been taken out of service, until remediation efforts are completed.

Follow-up testing on each fixture will be performed to ensure safe levels before returning to service.

As remediation are made, additional information and complete water testing results will become available on the district website.

Please contact me if you have any questions.

Sincerely,

A handwritten signature in black ink that reads "Timothy P. Ryan". The signature is written in a cursive style.

Timothy P. Ryan
Superintendent of Schools
(315) 683-5301
tryan@fabiuspompey.org

Date	Location	Results	Action
October 15, 2016	H.S. Boys' Lavatory, left sink	16 ppb	Turned Off
October 15, 2016	H.S. Boys' Lavatory, right-center sink	20 ppb	Turned Off
October 15, 2016	H.S. Girls' Lavatory, left sink	15 ppb	Posted Sign
October 15, 2016	H.S. Girls' Lavatory, left center sink	47 ppb	Posted sign
October 15, 2016	H.S. Girls' Lavatory, right center sink	19 ppb	Posted sign
October 15, 2016	H.S. Girls' Lavatory, right sink	17 ppb	Posted sign
October 15, 2016	H.S. Girls' Locker Room, fountain	37 ppb	Turned Off
October 15, 2016	District Office, sink	3022 ppb	Posted sign
October 15, 2016	Girls' Coaches Office, sink	22 ppb	Posted sign
October 15, 2016	M.S. Library, sink	67 ppb	Turned Off
October 15, 2106	M.S. Room 209, sink	31 ppb	Turned Off
October 15, 2016	Hallway Fountain	16 ppb	Turned Off