



Microbac Laboratories, Inc., New York Division
CERTIFICATE OF ANALYSIS

JOK1555

FABIUS POMEY SCHOOLS

Project Name: HS/MS

Rick Clancy
 1211 Mill Street
 Fabius, NY 13063

Project / PO Number: N/A
 Received: 11/12/2020
 Reported: 12/10/2020

Analytical Testing Parameters

Client Sample ID: H1 - District Office Sink	Collected By: RC-Client
Sample Matrix: Drinking Water	Collection Date: 02/17/2021 6:06
Lab Sample ID: J1B1256-02	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0027	0.0150 AL	0.0010	mg/L		02/24/21 1248	02/25/21 1002	DLO

Client Sample ID: H2	Collected By: RC-Client
Sample Matrix: Drinking Water	Collection Date: 11/11/2020 3:35
Lab Sample ID: JOK1555-02	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0066	0.0150 AL	0.0010	mg/L		12/02/20 0925	12/02/20 1104	LLW

Client Sample ID: H3	Collected By: RC-Client
Sample Matrix: Drinking Water	Collection Date: 11/11/2020 3:36
Lab Sample ID: JOK1555-03	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0034	0.0150 AL	0.0010	mg/L		12/02/20 0925	12/02/20 1106	LLW

Client Sample ID: H4	Collected By: RC-Client
Sample Matrix: Drinking Water	Collection Date: 11/11/2020 3:37
Lab Sample ID: JOK1555-04	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0103	0.0150 AL	0.0010	mg/L		12/02/20 0925	12/02/20 1108	LLW

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | www.microbac.com



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0K1555

Client Sample ID: H5	Sample Matrix: Drinking Water	Collected By: RC-Client
Lab Sample ID: J0K1555-05		Collection Date: 11/11/2020 3:38

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0010	0.0150 AL	0.0010	mg/L		12/02/20 0925	12/02/20 1110	LLW

Client Sample ID: H6	Sample Matrix: Drinking Water	Collected By: RC-Client
Lab Sample ID: J0K1555-06		Collection Date: 11/11/2020 3:39

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		12/02/20 0925	12/02/20 1112	LLW

Client Sample ID: H7	Sample Matrix: Drinking Water	Collected By: RC-Client
Lab Sample ID: J0K1555-07		Collection Date: 11/11/2020 3:41

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0029	0.0150 AL	0.0010	mg/L		12/02/20 0925	12/02/20 1117	LLW

Client Sample ID: H8	Sample Matrix: Drinking Water	Collected By: RC-Client
Lab Sample ID: J0K1555-08		Collection Date: 11/11/2020 3:42

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0072	0.0150 AL	0.0010	mg/L		12/02/20 0925	12/02/20 1119	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0K1555

Client Sample ID: H9	Sample Matrix: Drinking Water	Collected By: RC-Client
Lab Sample ID: J0K1555-09		Collection Date: 11/11/2020 3:44

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0068	0.0150 AL	0.0010	mg/L		12/02/20 0925	12/02/20 1121	LLW

Client Sample ID: H10	Sample Matrix: Drinking Water	Collected By: RC-Client
Lab Sample ID: J0K1555-10		Collection Date: 11/11/2020 3:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0058	0.0150 AL	0.0010	mg/L		12/02/20 0925	12/02/20 1123	LLW

Client Sample ID: H11	Sample Matrix: Drinking Water	Collected By: RC-Client
Lab Sample ID: J0K1555-11		Collection Date: 11/11/2020 3:47

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0047	0.0150 AL	0.0010	mg/L		12/02/20 0925	12/02/20 1124	LLW

Client Sample ID: H12	Sample Matrix: Drinking Water	Collected By: RC-Client
Lab Sample ID: J0K1555-12		Collection Date: 11/11/2020 3:48

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0068	0.0150 AL	0.0010	mg/L		12/02/20 0925	12/02/20 1128	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0K1555

Client Sample ID: H13	Sample Matrix: Drinking Water	Collected By: RC-Client
Lab Sample ID: J0K1555-13		Collection Date: 11/11/2020 3:49

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0015	0.0150 AL	0.0010	mg/L		12/02/20 0925	12/02/20 1130	LLW

Client Sample ID: H14	Sample Matrix: Drinking Water	Collected By: RC-Client
Lab Sample ID: J0K1555-14		Collection Date: 11/11/2020 3:52

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		12/02/20 0925	12/02/20 1132	LLW

Client Sample ID: H15	Sample Matrix: Drinking Water	Collected By: RC-Client
Lab Sample ID: J0K1555-15		Collection Date: 11/11/2020 3:53

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0041	0.0150 AL	0.0010	mg/L		12/02/20 0925	12/02/20 1134	LLW

Client Sample ID: H16	Sample Matrix: Drinking Water	Collected By: RC-Client
Lab Sample ID: J0K1555-16		Collection Date: 11/11/2020 3:56

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0014	0.0150 AL	0.0010	mg/L		12/02/20 0925	12/02/20 1139	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0K1555

Client Sample ID: H17	Collected By: RC-Client
Sample Matrix: Drinking Water	Collection Date: 11/11/2020 3:57
Lab Sample ID: J0K1555-17	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0013	0.0150 AL	0.0010	mg/L		12/02/20 0925	12/02/20 1141	LLW

Client Sample ID: H18 Girls Coach Sink	Collected By: RC-Client
Sample Matrix: Drinking Water	Collection Date: 02/17/2021 6:10
Lab Sample ID: J1B1256-03	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0125	0.0150 AL	0.0010	mg/L		02/24/21 1248	02/25/21 1004	DLO

Client Sample ID: H19	Collected By: RC-Client
Sample Matrix: Drinking Water	Collection Date: 11/11/2020 4:02
Lab Sample ID: J0K1555-19	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0018	0.0150 AL	0.0010	mg/L		12/02/20 0925	12/02/20 1145	LLW

Client Sample ID: H20	Collected By: RC-Client
Sample Matrix: Drinking Water	Collection Date: 11/11/2020 4:02
Lab Sample ID: J0K1555-20	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0022	0.0150 AL	0.0010	mg/L		12/02/20 0925	12/02/20 1146	LLW

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | www.microbac.com



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0K1555

Client Sample ID: H21	Collected By: RC-Client
Sample Matrix: Drinking Water	Collection Date: 11/11/2020 4:03
Lab Sample ID: J0K1555-21	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0069	0.0150 AL	0.0010	mg/L		12/02/20 1436	12/02/20 2045	LLW

Client Sample ID: H22	Collected By: RC-Client
Sample Matrix: Drinking Water	Collection Date: 11/11/2020 4:05
Lab Sample ID: J0K1555-22	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0023	0.0150 AL	0.0010	mg/L		12/02/20 1436	12/02/20 2051	LLW

Client Sample ID: H23	Collected By: RC-Client
Sample Matrix: Drinking Water	Collection Date: 11/11/2020 4:07
Lab Sample ID: J0K1555-23	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0031	0.0150 AL	0.0010	mg/L		12/02/20 1436	12/02/20 2053	LLW

Client Sample ID: H24	Collected By: RC-Client
Sample Matrix: Drinking Water	Collection Date: 11/11/2020 4:08
Lab Sample ID: J0K1555-24	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		12/02/20 1436	12/02/20 2055	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0K1555

Client Sample ID: H25	Collected By: RC-Client
Sample Matrix: Drinking Water	Collection Date: 11/11/2020 4:09
Lab Sample ID: J0K1555-25	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0020	0.0150 AL	0.0010	mg/L		12/02/20 1436	12/02/20 2057	LLW

Client Sample ID: H26	Collected By: RC-Client
Sample Matrix: Drinking Water	Collection Date: 11/11/2020 4:10
Lab Sample ID: J0K1555-26	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0026	0.0150 AL	0.0010	mg/L		12/02/20 1436	12/02/20 2059	LLW

Client Sample ID: H27	Collected By: RC-Client
Sample Matrix: Drinking Water	Collection Date: 11/11/2020 4:11
Lab Sample ID: J0K1555-27	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0019	0.0150 AL	0.0010	mg/L		12/02/20 1436	12/02/20 2105	LLW

Client Sample ID: H28	Collected By: RC-Client
Sample Matrix: Drinking Water	Collection Date: 11/11/2020 4:13
Lab Sample ID: J0K1555-28	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0048	0.0150 AL	0.0010	mg/L		12/02/20 1436	12/02/20 2107	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0K1555

Client Sample ID: H29	Collected By: RC-Client
Sample Matrix: Drinking Water	Collection Date: 11/11/2020 4:14
Lab Sample ID: J0K1555-29	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0018	0.0150 AL	0.0010	mg/L		12/02/20 1436	12/02/20 2109	LLW

Client Sample ID: H30	Collected By: RC-Client
Sample Matrix: Drinking Water	Collection Date: 11/11/2020 4:17
Lab Sample ID: J0K1555-30	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0057	0.0150 AL	0.0010	mg/L		12/02/20 1436	12/02/20 2111	LLW

Client Sample ID: H31	Collected By: RC-Client
Sample Matrix: Drinking Water	Collection Date: 11/11/2020 4:19
Lab Sample ID: J0K1555-31	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0119	0.0150 AL	0.0010	mg/L		12/02/20 1436	12/02/20 2113	LLW

Client Sample ID: H32	Collected By: RC-Client
Sample Matrix: Drinking Water	Collection Date: 11/11/2020 4:30
Lab Sample ID: J0K1555-32	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		12/02/20 1436	12/02/20 2117	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0K1555

Client Sample ID: H33	Sample Matrix: Drinking Water	Collected By: RC-Client
Lab Sample ID: J0K1555-33		Collection Date: 11/11/2020 4:21

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0029	0.0150 AL	0.0010	mg/L		12/02/20 1436	12/02/20 2119	LLW

Client Sample ID: H34	Sample Matrix: Drinking Water	Collected By: RC-Client
Lab Sample ID: J0K1555-34		Collection Date: 11/11/2020 4:23

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0028	0.0150 AL	0.0010	mg/L		12/02/20 1436	12/02/20 2121	LLW

Client Sample ID: H35	Sample Matrix: Drinking Water	Collected By: RC-Client
Lab Sample ID: J0K1555-35		Collection Date: 11/11/2020 4:24

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0038	0.0150 AL	0.0010	mg/L		12/02/20 1436	12/02/20 2123	LLW

Client Sample ID: H36	Sample Matrix: Drinking Water	Collected By: RC-Client
Lab Sample ID: J0K1555-36		Collection Date: 11/11/2020 4:26

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0043	0.0150 AL	0.0010	mg/L		12/02/20 1436	12/02/20 2128	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0K1555

Client Sample ID: H37	Collected By: RC-Client
Sample Matrix: Drinking Water	Collection Date: 11/11/2020 4:26
Lab Sample ID: J0K1555-37	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0091	0.0150 AL	0.0010	mg/L		12/02/20 1436	12/02/20 2131	LLW

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL: US EPA Action Level
- mg/L: Milligrams per Liter
- RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville 11549	New York State Department of Health
Microbac Laboratories, Inc., New York Division NY Lab ID No.: 10795	New York State Department of Health


Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <<https://www.microbac.com/standard-terms-conditions>>.**

Reviewed and Approved By:

Shannon Weeks
Customer Relationship Coordinator
Reported: 12/10/2020 21:42



3821 Buck Dr.
Cordland, NY 13045
607.753.3403

2389 Elmira St., Suite C
Sayre, PA 18840
570.888.0169

428 Route 315 Hwy
Pittston, PA 18640
570.348.0775

4359 Linglestown Rd.
Harrisburg, PA 17112
717.651.9700

3719 Garrett Rd.
Drexel Hill, PA 19026
484.461.9722

CHAIN OF CUSTODY RECORD

Number Instructions on back

Lab Report Address: Fabius Pompey CSD
Invoice Address: Fabius Pompey CSD
Turnaround Time: 13.4

Client Name: 1211 Mill St
Client Name: 1211 Mill St
Rush* (notify lab) Routine (5 to 7 business days)

Address: Fabius, N.Y. 13063
Address: Fabius, N.Y. 13063

City, State, Zip: Rick Clancy
City, State, Zip: Rick Clancy

Contact: (315) 446-5529
Contact: Rick Clancy

Telephone No.: (315) 446-5529
Telephone No.: (315) 440-5529

Send Report via: Mail e-mail (address)
Send Invoice via: Mail e-mail (address)

Project: Lead EPA 200.8
Location: H.S./MS. Water Dist.

Sampled by (PRINT): Rick Clancy
Sampler Signature: Rick Clancy

Sampler No.: (315) 440-5529
Sampler Phone No.: (315) 440-5529

* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

Lab ID	Client Sample ID (Location of sample taken. Ex: Kitchen sink, bathroom sink etc.)	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types	Requested Analysis	Additional Note
H1	dishnet office sink	11-11-20	3:33	1	DW	RC	U	Lead (EPA 200.8)	
H2	Kit dish sink	11-11-20	3:35	1	DW	RC	U		
H3	Kit cook sink	11-11-20	3:36	1	DW	RC	U		
H4	Kit prep sink	11-11-20	3:37	1	DW	RC	U		
H5	Main office sink	11-11-20	3:38	1	DW	RC	U		
H6	Hallway fountain	11-11-20	3:39	1	DW	RC	U		
H7	Library sink	11-11-20	3:41	1	DW	RC	U		
H8	Nurse Exam Sink	11-11-20	3:42	1	DW	RC	U		
H9	Nurse wash sink	11-11-20	3:44	1	DW	RC	U		
H10	Nurse Bath Sink	11-11-20	3:45	1	DW	RC	U		

Possible Hazard Identification: Hazardous Non-Hazardous
Sample Disposition: Dispose as appropriate Return Archive

Relinquished By (signature): Rick Clancy
Relinquished By (signature): Rick Clancy
Date/Time: 11/12/20
Date/Time: 9:20

Received By (signature): Shannon Weeks
Received By (signature): Shannon Weeks
Date/Time: 11/12/2020
Date/Time: 9:20

CHAIN OF CUSTODY RECORD

3821 Buck Dr.
Cortland, NY 13045
607.753.3403

2369 Elmira St., Suite C
Sayre, PA 18840
570.888.0169

428 Route 315 Hwy
Pittston, PA 18640
570.348.0775

4359 Linglestown Rd.
Harrisburg, PA 17112
717.651.9700

3719 Garrett Rd.
Drexel Hill, PA 19026
484.461.9722

Number Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C) 13.4

Therm ID 044

Holding Time

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

Level 2 Level 3 Level 4 EDD

Compliance Monitoring? Yes No

Agency/Program

Sampler Phone No.: (315) 440-5529

Project: Lead EPA 200.8

Lab Report Address Fabius Pompey CSB

Client Name: Rick Clancy

Address: 1211 Mill St.

City, State, Zip: Fabius, NY 13063

Contact: Rick Clancy

Telephone No.: (315) 446-5529

Invoice Address Fabius Pompey CSB

Client Name: Rick Clancy

Address: 1211 Mill St.

City, State, Zip: Fabius, NY 13063

Contact: Rick Clancy

Telephone No.: (315) 446-5529

Turnaround Time

Report Type

Results Only Level 1 Level 2 Level 3 Level 4 EDD

Mail Fax e-mail (address)

Send Invoice via: (315) 440-5529

Water Dist. PO No.:

Sampler Signature: Rick Clancy

Sampler Phone No.: (315) 440-5529

Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

Requested Analysis

Sample Disposition: Dispose as appropriate Return Archive

Lab ID	Client Sample ID (Location of sample taken. Ex: Kitchen sink, bathroom sink etc.)	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types	Additional Notes
H 11	H.S. Faculty (mens) bathroom sink	11-11-20	3:47	1	DW	RC	U	Lead (EPA 200.8)
H 12	H.S. Faculty (womens) bathroom sink	11-11-20	3:48	1	DW	RC	U	
H 13	H.S. Faculty Right	11-11-20	3:49	1	DW	RC	U	
H 14	Chorus Hall fountain	11-11-20	3:52	1	DW	RC	U	
H 15	Band rm. Sink	11-11-20	3:53	1	DW	RC	U	
H 16	H.S. girls locker left	11-11-20	3:56	1	DW	RC	U	
H 17	H.S. girls locker right	11-11-20	3:57	1	DW	RC	U	
H 18	girls coach sink	11-11-20	3:59	1	DW	RC	U	
H 19	rm 206 right rear	11-11-20	4:02	1	DW	RC	U	
H 20	rm 206 right front	11-11-20	4:02	1	DW	RC	U	

Relinquished By (signature) Rick Clancy Date/Time 11/12/20 9:20

Received By (signature) [Signature] Date/Time 11/12/2020 0920

Relinquished By (signature) Rick Clancy Date/Time 11/12/20 9:20

Received By (signature) [Signature] Date/Time 11/12/2020 0920

Relinquished By (signature) Rick Clancy Date/Time 11/12/20 9:20

Received By (signature) [Signature] Date/Time 11/12/2020 0920

Relinquished By (signature) Rick Clancy Date/Time 11/12/20 9:20

Received By (signature) [Signature] Date/Time 11/12/2020 0920

Comments: PLEASE RETURN SAMPLES ON ICE.

CHAIN OF CUSTODY RECORD

MICROBAC 3821 Buck Dr. 2369 Elmira St, Suite C 428 Route 315 Hwy 4399 Linglestown Rd. 3719 Garrett Rd. Number 13045 Cortland, NY 13045 Sayre, PA 18840 Pittston, PA 18640 Harrisburg, PA 17112 Drexel Hill, PA 19026 807.753.3403 570.888.0169 570.348.0775 570.348.0775 484.461.9722 484.461.9722

Instructions on back
TO BE COMPLETED BY MICROBAC
Temperature Upon Receipt (°C) 13.4
Therm ID *CHA*

Lab Report Address: *Fabius Pompey C-SD*
Client Name: *1211 Mill St*
Address: *1211 Mill St*
City, State, Zip: *Fabius, NY 13063*
Contact: *Rick Clancy*
Telephone No.: *(315) 440-5529*
Send Report via: Mail Fax e-mail (address)
Project: *Lead EPA 200.8*
Sampler Signature: *Rick Clancy*
Sampler Phone No.: *(315) 440-5529*

Invoice Address: *Fabius Pompey C-SD*
Client Name: *1211 Mill St*
Address: *1211 Mill St*
City, State, Zip: *Fabius, NY 13063*
Contact: *Rick Clancy*
Telephone No.: *(315) 440-5529*
Send Invoice via: Mail Fax e-mail (address)
Location: *H.S./MS.*
Water Dist. PO No.:
Report Type: *Turnaround Time*
Reported by: *Rick Clancy*
Compliance Monitoring? Yes No
Agency/Program: *clancyfabiuspompey.org*

Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)
Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

Lab ID	Client Sample ID (Location of sample taken. Ex: Kitchen sink, bathroom sink etc.)	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types	Additional Notes
H 21	rm 209 left rear	11-11-20	4:03	1	DW	RC	U	
H 22	rm 209 left front	11-11-20	4:05	1	DW	RC	U	
H 23	M.S. library sink	11-11-20	4:07	1	DW	RC	U	
H 24	Holloway fountain	11-11-20	4:08	1	DW	RC	U	
H 25	M.S. faculty mens	11-11-20	4:09	1	DW	RC	U	
H 26	MS faculty womens	11-11-20	4:10	1	DW	RC	U	
H 27	M.S. faculty Kit	11-11-20	4:11	1	DW	RC	U	
H 28	rm 209 sink	11-11-20	4:13	1	DW	RC	U	
H 29	rm 211 sink	11-11-20	4:14	1	DW	RC	U	
H 30	H.S. boys locker	11-11-20	4:17	1	DW	RC	U	

Possible Hazard Identification: Hazardous Non-Hazardous
Sample Disposition: Dispose as appropriate Return Archive
Relinquished By (signature): *Rick Clancy* Date/Time: *11/12/20 9:20*
Relinquished By (signature): *[Signature]* Date/Time: *11/12/20 9:20*
Received By (signature): *[Signature]* Date/Time: *11/12/20 9:20*
Received By (signature): *[Signature]* Date/Time: *11/12/20 9:20*

PLEASE RETURN SAMPLES ON ICE.

