



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5K0453

FABIUS POMEY SCHOOLS

Project Name: Elementary School - Lead

Rick Clancy
1211 Mill Street
Fabius, NY 13063

Project / PO Number: N/A
Received: 11/12/2025
Reported: 11/26/2025

Analytical Testing Parameters

Client Sample ID: E1 - (B) Low Drink Fountain
Sample Matrix: Drinking Water
Lab Sample ID: J5K0453-01
Collected By: Rick Clancy
Collection Date: 11/11/2025 16:00

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	<0.0010	0.0050 AL	0.0010	mg/L		11/20/25 1513	11/20/25 1837	DLO

Client Sample ID: E2 - (B) High Drink Fountain
Sample Matrix: Drinking Water
Lab Sample ID: J5K0453-02
Collected By: Rick Clancy
Collection Date: 11/11/2025 16:03

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	<0.0010	0.0050 AL	0.0010	mg/L		11/20/25 1513	11/20/25 1842	DLO

Client Sample ID: E3 - (G) Low Drink Fountain
Sample Matrix: Drinking Water
Lab Sample ID: J5K0453-03
Collected By: Rick Clancy
Collection Date: 11/11/2025 16:03

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	<0.0010	0.0050 AL	0.0010	mg/L		11/20/25 1513	11/20/25 1843	DLO

Client Sample ID: E4 - (G) High Drink Fountain
Sample Matrix: Drinking Water
Lab Sample ID: J5K0453-04
Collected By: Rick Clancy
Collection Date: 11/11/2025 16:04

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	<0.0010	0.0050 AL	0.0010	mg/L		11/20/25 1513	11/20/25 1845	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5K0453

Client Sample ID: E5 - Gym Foyer Fountain
Sample Matrix: Drinking Water
Lab Sample ID: J5K0453-05

Collected By: Rick Clancy
Collection Date: 11/11/2025 16:05

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Table with 9 columns: Metals Total by ICPMS, Method: EPA 200.8, Rv. 5.4 (1994), Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row 1: Lead, <0.0010, 0.0050 AL, 0.0010, mg/L, 11/20/25 1513, 11/20/25 1846, DLO

Client Sample ID: E6 - Room # 101 Sink
Sample Matrix: Drinking Water
Lab Sample ID: J5K0453-06

Collected By: Rick Clancy
Collection Date: 11/11/2025 16:07

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Table with 9 columns: Metals Total by ICPMS, Method: EPA 200.8, Rv. 5.4 (1994), Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row 1: Lead, 0.0039, 0.0050 AL, 0.0010, mg/L, 11/20/25 1513, 11/20/25 1848, DLO

Client Sample ID: E7 - Faculty Room Sink
Sample Matrix: Drinking Water
Lab Sample ID: J5K0453-07

Collected By: Rick Clancy
Collection Date: 11/11/2025 16:09

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Table with 9 columns: Metals Total by ICPMS, Method: EPA 200.8, Rv. 5.4 (1994), Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row 1: Lead, 0.0014, 0.0050 AL, 0.0010, mg/L, 11/20/25 1513, 11/20/25 1853, DLO

Client Sample ID: E8 - Kitchen Prep East Sink
Sample Matrix: Drinking Water
Lab Sample ID: J5K0453-08

Collected By: Rick Clancy
Collection Date: 11/11/2025 16:12

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Table with 9 columns: Metals Total by ICPMS, Method: EPA 200.8, Rv. 5.4 (1994), Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row 1: Lead, 0.0018, 0.0050 AL, 0.0010, mg/L, 11/20/25 1513, 11/20/25 1854, DLO

Client Sample ID: E9 - Kitchen Pot Sink
Sample Matrix: Drinking Water
Lab Sample ID: J5K0453-09

Collected By: Rick Clancy
Collection Date: 11/11/2025 16:13

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Table with 9 columns: Metals Total by ICPMS, Method: EPA 200.8, Rv. 5.4 (1994), Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row 1: Lead, <0.0010, 0.0050 AL, 0.0010, mg/L, 11/20/25 1513, 11/20/25 1856, DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5K0453

Client Sample ID: E10 - Kitchen Prep Center Sink	Collected By: Rick Clancy
Sample Matrix: Drinking Water	Collection Date: 11/11/2025 16:13
Lab Sample ID: J5K0453-10	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	<0.0010	0.0050 AL	0.0010	mg/L		11/20/25 1513	11/20/25 1857	DLO

Client Sample ID: E11 - Kitchen Wash West Sink	Collected By: Rick Clancy
Sample Matrix: Drinking Water	Collection Date: 11/11/2025 16:14
Lab Sample ID: J5K0453-11	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	0.0013	0.0050 AL	0.0010	mg/L		11/20/25 1513	11/20/25 1859	DLO

Client Sample ID: E12 - Ice Maker	Collected By: Rick Clancy
Sample Matrix: Drinking Water	Collection Date: 11/11/2025 16:15
Lab Sample ID: J5K0453-12	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	<0.0010	0.0050 AL	0.0010	mg/L		11/20/25 1513	11/20/25 1902	DLO

Client Sample ID: E13 - Room # 117 Left Sink	Collected By: Rick Clancy
Sample Matrix: Drinking Water	Collection Date: 11/11/2025 16:22
Lab Sample ID: J5K0453-13	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	<0.0010	0.0050 AL	0.0010	mg/L		11/20/25 1513	11/20/25 1903	DLO

Client Sample ID: E14 - Room # 117 Right Sink	Collected By: Rick Clancy
Sample Matrix: Drinking Water	Collection Date: 11/11/2025 16:22
Lab Sample ID: J5K0453-14	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	0.0016	0.0050 AL	0.0010	mg/L		11/20/25 1513	11/20/25 1905	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5K0453

Client Sample ID: E15 - Room # 116 Sink	Collected By: Rick Clancy
Sample Matrix: Drinking Water	Collection Date: 11/11/2025 16:24
Lab Sample ID: J5K0453-15	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	0.0010	0.0050 AL	0.0010	mg/L		11/20/25 1513	11/20/25 1906	DLO

Client Sample ID: E16 - Low Drink Fountain (118)	Collected By: Rick Clancy
Sample Matrix: Drinking Water	Collection Date: 11/11/2025 16:26
Lab Sample ID: J5K0453-16	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	<0.0010	0.0050 AL	0.0010	mg/L		11/20/25 1513	11/20/25 1911	DLO

Client Sample ID: E17 - High Drink Fountain (118)	Collected By: Rick Clancy
Sample Matrix: Drinking Water	Collection Date: 11/11/2025 16:26
Lab Sample ID: J5K0453-17	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	<0.0010	0.0050 AL	0.0010	mg/L		11/20/25 1513	11/20/25 1912	DLO

Client Sample ID: E18 - Room # 118 Sink	Collected By: Rick Clancy
Sample Matrix: Drinking Water	Collection Date: 11/11/2025 16:28
Lab Sample ID: J5K0453-18	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	0.103	0.0050 AL	0.0010	mg/L		11/21/25 1502	11/24/25 1601	DLO

Client Sample ID: E19 - Room # 119 Sink	Collected By: Rick Clancy
Sample Matrix: Drinking Water	Collection Date: 11/11/2025 16:30
Lab Sample ID: J5K0453-19	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	0.0021	0.0050 AL	0.0010	mg/L		11/20/25 1513	11/20/25 1914	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5K0453

Client Sample ID: E20 - Room # 120 Sink
Sample Matrix: Drinking Water
Lab Sample ID: J5K0453-20
Collected By: Rick Clancy
Collection Date: 11/11/2025 16:31

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Table with 9 columns: Metals Total by ICPMS, Method: EPA 200.8, Rv. 5.4 (1994), Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead: 0.0021, 0.0050 AL, 0.0010, mg/L, 11/20/25 1513, 11/20/25 1916, DLO

Client Sample ID: E21 - Room # 121 Sink
Sample Matrix: Drinking Water
Lab Sample ID: J5K0453-21
Collected By: Rick Clancy
Collection Date: 11/11/2025 16:32

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Table with 9 columns: Metals Total by ICPMS, Method: EPA 200.8, Rv. 5.4 (1994), Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead: 0.0022, 0.0050 AL, 0.0010, mg/L, 11/20/25 1513, 11/20/25 1917, DLO

Client Sample ID: E22 - Room # 122 Sink
Sample Matrix: Drinking Water
Lab Sample ID: J5K0453-22
Collected By: Rick Clancy
Collection Date: 11/11/2025 16:35

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Table with 9 columns: Metals Total by ICPMS, Method: EPA 200.8, Rv. 5.4 (1994), Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead: 0.0018, 0.0050 AL, 0.0010, mg/L, 11/20/25 1505, 11/20/25 1925, DLO

Client Sample ID: E23 - Room # 123 Sink
Sample Matrix: Drinking Water
Lab Sample ID: J5K0453-23
Collected By: Rick Clancy
Collection Date: 11/11/2025 16:38

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Table with 9 columns: Metals Total by ICPMS, Method: EPA 200.8, Rv. 5.4 (1994), Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead: 0.0035, 0.0050 AL, 0.0010, mg/L, 11/20/25 1505, 11/20/25 1929, DLO

Client Sample ID: E24 - Room # 124 Sink
Sample Matrix: Drinking Water
Lab Sample ID: J5K0453-24
Collected By: Rick Clancy
Collection Date: 11/11/2025 16:39

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Table with 9 columns: Metals Total by ICPMS, Method: EPA 200.8, Rv. 5.4 (1994), Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead: 0.0021, 0.0050 AL, 0.0010, mg/L, 11/20/25 1505, 11/20/25 1931, DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5K0453

Client Sample ID: E25 - Room # 125 Sink	
Sample Matrix: Drinking Water	Collected By: Rick Clancy
Lab Sample ID: J5K0453-25	Collection Date: 11/11/2025 16:40

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0013	0.0050 AL	0.0010	mg/L		11/20/25 1505	11/20/25 1932	DLO

Client Sample ID: E26 - Room # 218 Sink	
Sample Matrix: Drinking Water	Collected By: Rick Clancy
Lab Sample ID: J5K0453-26	Collection Date: 11/11/2025 16:44

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0010	0.0050 AL	0.0010	mg/L		11/20/25 1505	11/20/25 1934	DLO

Client Sample ID: E27 - Room # 216 Sink	
Sample Matrix: Drinking Water	Collected By: Rick Clancy
Lab Sample ID: J5K0453-27	Collection Date: 11/11/2025 16:46

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0011	0.0050 AL	0.0010	mg/L		11/20/25 1505	11/20/25 1935	DLO

Client Sample ID: E28 - Room # 217 Sink	
Sample Matrix: Drinking Water	Collected By: Rick Clancy
Lab Sample ID: J5K0453-28	Collection Date: 11/11/2025 16:46

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0061	0.0050 AL	0.0010	mg/L		11/20/25 1505	11/20/25 1940	DLO

Client Sample ID: E29 - Room # 215 Sink	
Sample Matrix: Drinking Water	Collected By: Rick Clancy
Lab Sample ID: J5K0453-29	Collection Date: 11/11/2025 16:48

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0314	0.0050 AL	0.0010	mg/L		11/21/25 1502	11/24/25 1606	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5K0453

Client Sample ID: E30 - Low Drink Fountain (215)	Collected By: Rick Clancy
Sample Matrix: Drinking Water	Collection Date: 11/11/2025 16:50
Lab Sample ID: J5K0453-30	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		11/20/25 1505	11/20/25 1941	DLO

Client Sample ID: E31 - High Drink Fountain (215)	Collected By: Rick Clancy
Sample Matrix: Drinking Water	Collection Date: 11/11/2025 16:51
Lab Sample ID: J5K0453-31	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		11/20/25 1505	11/20/25 1943	DLO

Client Sample ID: E32 - Nurses Office Exam Room	Collected By: Rick Clancy
Sample Matrix: Drinking Water	Collection Date: 11/11/2025 16:52
Lab Sample ID: J5K0453-32	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0026	0.0050 AL	0.0010	mg/L		11/20/25 1505	11/20/25 1945	DLO

Client Sample ID: E33 - Nurses Bathroom Sink	Collected By: Rick Clancy
Sample Matrix: Drinking Water	Collection Date: 11/11/2025 16:52
Lab Sample ID: J5K0453-33	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0027	0.0050 AL	0.0010	mg/L		11/20/25 1505	11/20/25 1946	DLO

Client Sample ID: E34 - Low Drink Fountain (202)	Collected By: Rick Clancy
Sample Matrix: Drinking Water	Collection Date: 11/11/2025 16:55
Lab Sample ID: J5K0453-34	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0050 AL	0.0010	mg/L		11/20/25 1505	11/20/25 1949	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5K0453

Client Sample ID: E35 - High Drink Fountain (202)	Collected By: Rick Clancy
Sample Matrix: Drinking Water	Collection Date: 11/11/2025 16:56
Lab Sample ID: J5K0453-35	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	<0.0010	0.0050 AL	0.0010	mg/L		11/20/25 1505	11/20/25 1951	DLO

Client Sample ID: E36 - Room # 221 Sink	Collected By: Rick Clancy
Sample Matrix: Drinking Water	Collection Date: 11/11/2025 16:57
Lab Sample ID: J5K0453-36	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	0.0063	0.0050 AL	0.0010	mg/L		11/20/25 1505	11/20/25 1952	DLO

Client Sample ID: E37 - Room # 315 Sink	Collected By: Rick Clancy
Sample Matrix: Drinking Water	Collection Date: 11/11/2025 17:01
Lab Sample ID: J5K0453-37	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	0.0029	0.0050 AL	0.0010	mg/L		11/20/25 1505	11/20/25 1954	DLO

Client Sample ID: E38 - Room # 314 Sink	Collected By: Rick Clancy
Sample Matrix: Drinking Water	Collection Date: 11/11/2025 17:02
Lab Sample ID: J5K0453-38	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	0.0010	0.0050 AL	0.0010	mg/L		11/20/25 1505	11/20/25 1958	DLO

Client Sample ID: E39 - Low Drink Fountain (313)	Collected By: Rick Clancy
Sample Matrix: Drinking Water	Collection Date: 11/11/2025 17:03
Lab Sample ID: J5K0453-39	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS Method: EPA 200.8, Rv. 5.4 (1994)	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Lead	<0.0010	0.0050 AL	0.0010	mg/L		11/20/25 1505	11/20/25 2000	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5K0453

Client Sample ID: E40 - High Drink Fountain (313)
Sample Matrix: Drinking Water
Lab Sample ID: J5K0453-40
Collected By: Rick Clancy
Collection Date: 11/11/2025 17:04

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Table with 9 columns: Metals Total by ICPMS, Method: EPA 200.8, Rv. 5.4 (1994), Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead shows result <0.0010.

Client Sample ID: E41 - Library Office Sink
Sample Matrix: Drinking Water
Lab Sample ID: J5K0453-41
Collected By: Rick Clancy
Collection Date: 11/11/2025 17:06

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Table with 9 columns: Metals Total by ICPMS, Method: EPA 200.8, Rv. 5.4 (1994), Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead shows result 0.0112.

Client Sample ID: E42 - Low Drink Fountain (302)
Sample Matrix: Drinking Water
Lab Sample ID: J5K0453-42
Collected By: Rick Clancy
Collection Date: 11/11/2025 17:07

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Table with 9 columns: Metals Total by ICPMS, Method: EPA 200.8, Rv. 5.4 (1994), Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead shows result <0.0010.

Client Sample ID: E43 - High Drink Fountain (302)
Sample Matrix: Drinking Water
Lab Sample ID: J5K0453-43
Collected By: Rick Clancy
Collection Date: 11/11/2025 17:08

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Table with 9 columns: Metals Total by ICPMS, Method: EPA 200.8, Rv. 5.4 (1994), Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead shows result <0.0010.

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL: US EPA Action Level
mg/L: Milligrams per Liter
RL: Reporting Limit



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J5K0453

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville
11549

New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.***

Reviewed and Approved By:

A handwritten signature in cursive script that reads "Renee Lantz".

Renee Lantz

Customer Relationship Specialist

Reported: 11/26/2025 08:26

CHAIN OF CUSTODY RECORD

Number: 3719 Garrett Rd.
 Instructions on back: Drexel Hill, PA 19028
 TO BE COMPLETED BY MICROBAC: 484.461.9722

Lab Report Address: 2369 Elmira St., Suite C
 Invoiced Address: 4359 Linglestown Rd.
 Client Name: Fabius Pompey CSJ
 Routine (5 to 7 business days): Harrisburg, PA 17112
 Turnaround Time: 717.651.9700

Client Name: Fabius Pompey CSJ
 Address: 1211 Hill St.
 City, State, Zip: Fabius, N.Y. 13063
 Contact: Rick Clancy
 Telephone No.: (315) 440-5529
 Send Report via: [] Mail [] Fax [] e-mail (address)

Project: LEAD EPA 200.8
 Location: E.S.
 Water Dist. PO No.:
 Sampler Signature: Rick Clancy
 Sampler Phone No.: (315) 440-5529

Temperature Upon Receipt (°C): 4.9
 Therm ID: IR-1
 Holding Time:
 Samples Received on Ice? Yes No N/A
 Custody Seals Intact? Yes No N/A

Compliance Monitoring? Yes No
 Agency/Program: relay of fabius pompey.org

Matrix: DW/PL
 No. of Containers: 1
 Grab / Comp: U
 Preservative Types: U

Client Sample ID (Location of sample taken):
 E1 (B) low drink fountain
 E2 (B) high drink fountain
 E3 (G) low drink fountain
 E4 (G) high drink fountain
 E5 gym fayer fountain
 E6 rm # 101 sink
 E7 faculty rm sink
 E8 Kit prep east sink
 E9 Kit prep sink
 E10 Kit prep center sink

Date Collected: 11-11-25
 Time Collected: 4:00
 Relinquished By (signature): SEE PAGE 5
 Relinquished By (signature): HNO3 ADDED TO SAMPLES
 Relinquished By (signature): J533019 - RLF 11/14/25

Requested Analysis: LEAD
 Matrix: DW/PL
 No. of Containers: 1
 Grab / Comp: U
 Preservative Types: U

Sample Disposition: Dispose as appropriate
 Received By (signature): Cassander Belle
 Date/Time: 11/21/25 8:40

Sample Disposition: Return Archive
 Received By (signature):
 Date/Time:

Sample Disposition: Non-Hazardous Radioactive
 Received By (signature):
 Date/Time:

Sample Disposition: Return Archive
 Received By (signature):
 Date/Time:

Barcode: J 5 K 0 4 5 3
 FABIUS POMPEY SCHOOLS
 PM: Joseph Palanza

Requested Analysis: LEAD
 Matrix: DW/PL
 No. of Containers: 1
 Grab / Comp: U
 Preservative Types: U

Sample Disposition: Dispose as appropriate
 Received By (signature):
 Date/Time:

Sample Disposition: Non-Hazardous Radioactive
 Received By (signature):
 Date/Time:

Sample Disposition: Return Archive
 Received By (signature):
 Date/Time:

Requested Analysis: LEAD
 Matrix: DW/PL
 No. of Containers: 1
 Grab / Comp: U
 Preservative Types: U

Sample Disposition: Dispose as appropriate
 Received By (signature):
 Date/Time:

Sample Disposition: Non-Hazardous Radioactive
 Received By (signature):
 Date/Time:

Sample Disposition: Return Archive
 Received By (signature):
 Date/Time:

Sample Disposition: Return Archive
 Received By (signature):
 Date/Time:

Requested Analysis: LEAD
 Matrix: DW/PL
 No. of Containers: 1
 Grab / Comp: U
 Preservative Types: U

Sample Disposition: Dispose as appropriate
 Received By (signature):
 Date/Time:

Sample Disposition: Non-Hazardous Radioactive
 Received By (signature):
 Date/Time:

Sample Disposition: Return Archive
 Received By (signature):
 Date/Time:

Sample Disposition: Return Archive
 Received By (signature):
 Date/Time:

Requested Analysis: LEAD
 Matrix: DW/PL
 No. of Containers: 1
 Grab / Comp: U
 Preservative Types: U

Sample Disposition: Dispose as appropriate
 Received By (signature):
 Date/Time:

Sample Disposition: Non-Hazardous Radioactive
 Received By (signature):
 Date/Time:

Sample Disposition: Return Archive
 Received By (signature):
 Date/Time:

Sample Disposition: Return Archive
 Received By (signature):
 Date/Time:

Requested Analysis: LEAD
 Matrix: DW/PL
 No. of Containers: 1
 Grab / Comp: U
 Preservative Types: U

Sample Disposition: Dispose as appropriate
 Received By (signature):
 Date/Time:

Sample Disposition: Non-Hazardous Radioactive
 Received By (signature):
 Date/Time:

Sample Disposition: Return Archive
 Received By (signature):
 Date/Time:

Sample Disposition: Return Archive
 Received By (signature):
 Date/Time:

Requested Analysis: LEAD
 Matrix: DW/PL
 No. of Containers: 1
 Grab / Comp: U
 Preservative Types: U

Sample Disposition: Dispose as appropriate
 Received By (signature):
 Date/Time:

Sample Disposition: Non-Hazardous Radioactive
 Received By (signature):
 Date/Time:

Sample Disposition: Return Archive
 Received By (signature):
 Date/Time:

Sample Disposition: Return Archive
 Received By (signature):
 Date/Time:

Requested Analysis: LEAD
 Matrix: DW/PL
 No. of Containers: 1
 Grab / Comp: U
 Preservative Types: U

Sample Disposition: Dispose as appropriate
 Received By (signature):
 Date/Time:

Sample Disposition: Non-Hazardous Radioactive
 Received By (signature):
 Date/Time:

Sample Disposition: Return Archive
 Received By (signature):
 Date/Time:

Sample Disposition: Return Archive
 Received By (signature):
 Date/Time:

Requested Analysis: LEAD
 Matrix: DW/PL
 No. of Containers: 1
 Grab / Comp: U
 Preservative Types: U

Sample Disposition: Dispose as appropriate
 Received By (signature):
 Date/Time:

Sample Disposition: Non-Hazardous Radioactive
 Received By (signature):
 Date/Time:

Sample Disposition: Return Archive
 Received By (signature):
 Date/Time:

Sample Disposition: Return Archive
 Received By (signature):
 Date/Time:

Requested Analysis: LEAD
 Matrix: DW/PL
 No. of Containers: 1
 Grab / Comp: U
 Preservative Types: U

Sample Disposition: Dispose as appropriate
 Received By (signature):
 Date/Time:

Sample Disposition: Non-Hazardous Radioactive
 Received By (signature):
 Date/Time:

Sample Disposition: Return Archive
 Received By (signature):
 Date/Time:

Sample Disposition: Return Archive
 Received By (signature):
 Date/Time:

Requested Analysis: LEAD
 Matrix: DW/PL
 No. of Containers: 1
 Grab / Comp: U
 Preservative Types: U

Sample Disposition: Dispose as appropriate
 Received By (signature):
 Date/Time:

Sample Disposition: Non-Hazardous Radioactive
 Received By (signature):
 Date/Time:

Sample Disposition: Return Archive
 Received By (signature):
 Date/Time:

Sample Disposition: Return Archive
 Received By (signature):
 Date/Time:

Requested Analysis: LEAD
 Matrix: DW/PL
 No. of Containers: 1
 Grab / Comp: U
 Preservative Types: U

Sample Disposition: Dispose as appropriate
 Received By (signature):
 Date/Time:

Sample Disposition: Non-Hazardous Radioactive
 Received By (signature):
 Date/Time:

Sample Disposition: Return Archive
 Received By (signature):
 Date/Time:

Sample Disposition: Return Archive
 Received By (signature):
 Date/Time:

Requested Analysis: LEAD
 Matrix: DW/PL
 No. of Containers: 1
 Grab / Comp: U
 Preservative Types: U

Sample Disposition: Dispose as appropriate
 Received By (signature):
 Date/Time:

Sample Disposition: Non-Hazardous Radioactive
 Received By (signature):
 Date/Time:

Sample Disposition: Return Archive
 Received By (signature):
 Date/Time:

Sample Disposition: Return Archive
 Received By (signature):
 Date/Time:

Requested Analysis: LEAD
 Matrix: DW/PL
 No. of Containers: 1
 Grab / Comp: U
 Preservative Types: U

Sample Disposition: Dispose as appropriate
 Received By (signature):
 Date/Time:

Sample Disposition: Non-Hazardous Radioactive
 Received By (signature):
 Date/Time:

Sample Disposition: Return Archive
 Received By (signature):
 Date/Time:

Sample Disposition: Return Archive
 Received By (signature):
 Date/Time:

Requested Analysis: LEAD
 Matrix: DW/PL
 No. of Containers: 1
 Grab / Comp: U
 Preservative Types: U

Sample Disposition: Dispose as appropriate
 Received By (signature):
 Date/Time:

Sample Disposition: Non-Hazardous Radioactive
 Received By (signature):
 Date/Time:

Sample Disposition: Return Archive
 Received By (signature):
 Date/Time:

Sample Disposition: Return Archive
 Received By (signature):
 Date/Time:

Requested Analysis: LEAD
 Matrix: DW/PL
 No. of Containers: 1
 Grab / Comp: U
 Preservative Types: U

Sample Disposition: Dispose as appropriate
 Received By (signature):
 Date/Time:

Sample Disposition: Non-Hazardous Radioactive
 Received By (signature):
 Date/Time:

Sample Disposition: Return Archive
 Received By (signature):
 Date/Time:

Sample Disposition: Return Archive
 Received By (signature):
 Date/Time:

Requested Analysis: LEAD
 Matrix: DW/PL
 No. of Containers: 1
 Grab / Comp: U
 Preservative Types: U

Sample Disposition: Dispose as appropriate
 Received By (signature):
 Date/Time:

Sample Disposition: Non-Hazardous Radioactive
 Received By (signature):
 Date/Time:

Sample Disposition: Return Archive
 Received By (signature):
 Date/Time:

Sample Disposition: Return Archive
 Received By (signature):
 Date/Time:

Requested Analysis: LEAD
 Matrix: DW/PL
 No. of Containers: 1
 Grab / Comp: U
 Preservative Types: U

Sample Disposition: Dispose as appropriate
 Received By (signature):
 Date/Time:

Sample Disposition: Non-Hazardous Radioactive
 Received By (signature):
 Date/Time:

Sample Disposition: Return Archive
 Received By (signature):
 Date/Time:

Sample Disposition: Return Archive
 Received By (signature):
 Date/Time:

CHAIN OF CUSTODY RECORD

3821 Buck Dr.
Cortland, NY 13045
607.753.3403

2389 Elmira St., Suite C
Sayre, PA 18840
607.888.0169

428 Route 315 Hwy
Pittston, PA 18640
570.348.0775

4359 Lingletown Rd.
Harrisburg, PA 17112
717.651.9700

3719 Garrett Rd.
Drexel Hill, PA 19026
484.461.9722

Instructions on back

Lab Report Address: **Fabius Pompey CSD**
 Client Name: **Fabius Pompey CSD**
 Address: **7800 Main St.**
 City, State, Zip: **Fabius, N.Y. 13063**
 Contact: **Rick Clancy**
 Telephone No.: **(315) 440-5529**
 Send Report via: Mail Fax e-mail (address)
 Project: **LEAD EPA 200.8**
 Location: **E.S.**
 Water Dist. **re-lancyefabiuspompey.org**

Invoice Address: **1211 Mill St.**
 Client Name: **Fabius Pompey CSD**
 City, State, Zip: **Fabius, N.Y. 13063**
 Contact: **Rick Clancy**
 Telephone No.: **(315) 440-5529**
 Send Invoice via: Mail Fax e-mail (address)
 PO No.: **re-lancyefabiuspompey.org**

Turnaround Time: **4.9**
 Temperature Upon Receipt (°C): **4.9**
 Therm ID: **IR-1**
 Holding Time: **re-lancyefabiuspompey.org**


Samples Received on Ice: Yes No **N/A**
 Custody Seals Intact?: Yes No **N/A**

Compliance Monitoring? Yes No
 () Agency/Program

Sampler Phone No.: **(315) 440-5529**

Sampled by (PRINT): **Rick Clancy**
 Signature: *Rick Clancy*
 Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)
 ** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

Lab ID	Client Sample ID (Location of sample taken. Ex: Kitchen sink, bathroom sink etc.)	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types	Sample Disposition	Relinquished By (signature)	Date/Time	Received By (signature)	Date/Time
E11	Kit wash west sink	11-15	4:14	1	DW/RL	RL	U	Disposal as appropriate	<i>P.M.</i>		<i>Car... ..</i>	11/25 8:40
E12	ice maker		4:15	1	DW/RL	RL	U	Disposal as appropriate				
E13	rm # 117 left sink		4:22	1	DW/RL	RL	U	Disposal as appropriate				
E14	rm # 117 right sink		4:22	1	DW/RL	RL	U	Disposal as appropriate				
E15	rm # 116 sink		4:24	1	DW/RL	RL	U	Disposal as appropriate				
E16	low drink fount. (118)		4:26	1	DW/RL	RL	U	Disposal as appropriate				
E17	high drink fount. (118)		4:28	1	DW/RL	RL	U	Disposal as appropriate				
E18	rm # 118 sink		4:30	1	DW/RL	RL	U	Disposal as appropriate				
E19	rm # 119 sink		4:30	1	DW/RL	RL	U	Disposal as appropriate				
E20	rm # 120 sink	11-15	4:31	1	DW/RL	RL	U	Disposal as appropriate				



Requested Analysis: **LEAD**

Comments: **PLEASE RETURN SAMPLES ON ICE.**

Relinquished By (signature): *P.M.*
 Date/Time: **11-15 4:14**

Received By (signature): *Car... ..*
 Date/Time: **11/25 8:40**

CHAIN OF CUSTODY RECORD

3719 Garrett Rd.
Drexel Hill, PA 19026
484.461.9722

4359 Linglestown Rd.
Harrisburg, PA 17112
717.651.9700

428 Route 315 Hwy
Pittston, PA 18640
570.348.0775

2369 Elmira St., Suite C
Sayre, PA 18840
570.888.0169

3821 Buck Dr.
Cortland, NY 13045
607.753.3403

Number Instructions on back

Turnaround Time

Invoice Address

Lab Report Address

TO BE COMPLETED BY MICROBAC
Temperature Upon Receipt (°C) 4.9
Therm ID IR-1
Holding Time

Client Name: Fabius Pompey CSX
Routine (5 to 7 business days)
RUSH* (notify lab)

Client Name: Fabius Pompey CSX

Samples Received on Ice? Yes No N/A
Custody Seals Intact? Yes No N/A

Results Only Level 1 Level 2 Level 3 Level 4 EDD
Mail Fax e-mail (address)
Send Invoice via: Mail Fax e-mail (address)

Address: 7800 Main St.
City, State, Zip: Fabius, N.Y. 13063
Contact: Rick Clancy
Telephone No.: (315) 440-5529
Send Invoice via: Mail Fax e-mail (address)

Compliance Monitoring? Yes No
Agency/Program

Report Type
Water Dist. E.S.

Location: E.S.

Sampler Phone No.: (315) 440-5529

Sampler Signature: Rick Clancy


Sampler Signature: Rick Clancy

Matrix Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

Preservative Types

Requested Analysis

Lab ID	Client Sample ID (Location of sample taken. Ex: Kitchen sink, bathroom sink etc.)	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types	Sample Disposition	Relinquished By (signature)	Date/Time	Received By (signature)	Date/Time
E31	high drink fount (215)	11-25	4:51	1	DW/PL	PL	U	✓	<u>P.H.</u>		<u>Cassandra Walker</u>	11/25 8:40
E32	Nurses off. exam rm		4:52	1	DW/PL	PL	U	✓				
E33	Nurses bath rm sink		4:52	1	DW/PL	PL	U	✓				
E34	low drink fount (202)		4:55	1	DW/PL	PL	U	✓				
E35	high drink fount (202)		4:56	1	DW/PL	PL	U	✓				
E36	rm # 321 sink		4:57	1	DW/PL	PL	U	✓				
E37	rm # 315 sink		5:01	1	DW/PL	PL	U	✓				
E38	rm # 314 sink		5:02	1	DW/PL	PL	U	✓				
E39	low drink fount (313)		5:03	1	DW/PL	PL	U	✓				
E40	high drink fount (313)	11-25	5:04	1	DW/PL	PL	U	✓				



PLEASE RETURN SAMPLES ON ICE.

CHAIN OF CUSTODY RECORD

3821 Buck Dr.
Cortland, NY 13045
607.753.3403

2369 Elmira St., Suite C
Sayre, PA 16840
570.888.0169

428 Route 315 Hwy
Pittston, PA 18640
570.348.0775

4359 Lingiestown Rd.
Harrisburg, PA 17112
717.651.9700

3719 Garrett Rd.
Drexel Hill, PA 19026
484.461.9722

Lab Report Address

Client Name: **Fabius Pompey CSB** Client Name: **Fabius Pompey CSB**

Address: **7800 Main St.** Address: **1211 Hill St.**

City, State, Zip: **Fabius, N.Y. 13063** City, State, Zip: **Fabius, N.Y. 13063**

Contact: **Rick Clancy** Contact: **Rick Clancy**

Telephone No.: **(315) 440-5529** Telephone No.: **(315) 440-5529**

Send Report via: Mail Fax e-mail (address) **relancey@fabiuspompey.org**

Project: **LEAD EPA 200.8** Location: **E.S.** Water Dist. **PO No.:**

Sampler Signature: **Rick Clancy** Sampler Phone No.: **(315) 440-5529**

Matrix Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Hexane, (U) Unpreserved

** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Hexane, (U) Unpreserved

Client Sample ID (Location of sample taken. Ex: Kitchen sink, bathroom sink etc.)

Date Collected

Time Collected

No. of Containers

Matrix

Grab / Comp

Preservative Types

Sample Disposition

Relinquished By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Relinquished By (signature)

Date/Time



J 5 K 0 4 5 3
FABIUS POMPEY SCHOOLS
PM: Joseph Palanza

REQUESTED ANALYSIS

Lab ID	Client Sample ID (Location of sample taken. Ex: Kitchen sink, bathroom sink etc.)	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types	Sample Disposition	Relinquished By (signature)	Date/Time	Relinquished By (signature)	Date/Time
E41	Library off. sink	11-11-25	5:06	1	DW RL	RL	U	X	<i>[Signature]</i>	11-12-25 8:40	<i>[Signature]</i>	11-12-25 8:40
E42	low drink faucet (30A)	11-11-25	5:07	1	DW RL	RL	U	X	<i>[Signature]</i>	11-12-25 8:40	<i>[Signature]</i>	11-12-25 8:40
E43	high drink faucet (30A)	11-11-25	5:08	1	DW RL	RL	U	X	<i>[Signature]</i>	11-12-25 8:40	<i>[Signature]</i>	11-12-25 8:40

PLEASE RETURN SAMPLES ON ICE.